

CERTIFICATE

TÜV NORD Systems GmbH & Co. KG, Hamburg,
confirms


Böllhoff Verbindungstechnik GmbH, Bielefeld:

Duct-connections between sheet metal air ducts with rectangular sections
and the belonging flanges manufactured with the joining tool

RIVCLINCH[®]


(Type: SC 0404IP V3M AERO)

fulfill the requirements according to DIN EN 1507:2006 regarding the
Air tightness class D.



Details are documented in the TÜV NORD Test Report No. 81 06 04 97 89.

TÜV NORD Systems GmbH & Co. KG
Abteilung Gebäudetechnik



Dipl.-Ing. (FH) M. Lukas

Essen, 18. Januar 2011